

令和3年8月度 水質検査結果表

項目	水質基準	定量下限値	千代川系							
			北古世町 1丁目 春日坂	曾我部町 犬飼 前川	東本梅町 東大谷 生子田	蔦田野町 佐伯 飼条	河原林 勝林島 稻荷	旭町 岩ヶ谷	畑野町 千ヶ畑 鎌ヶ谷	畑野町 土ヶ畑 沢ノ上
採水日			10	10	10	10	3	3	17	17
時間			8:55	11:12	12:13	11:41	13:48	14:40	12:33	12:57
天候			曇	晴	曇	晴	曇	曇	雨	雨
気温			26.0	27.5	28.3	30.5	27.0	27.2	21.7	21.2
水温			21.0	27.3	26.6	20.9	28.3	28.7	23.6	24.2
区分			浄水	浄水	浄水	浄水	浄水	浄水	浄水	浄水
1 一般細菌	100個/ml以下	0個/ml	0	0	0	0	0	0	0	0
2 大腸菌	検出されないこと	—	(-)	(-)	(-)	(-)	(-)	(-)	(-)	(-)
10 シアン化物イオン及び塩化シアン	0.01mg/l以下	0.001mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
11 硝酸態窒素及び亜硝酸態窒素	10mg/l以下	0.02mg/l	0.75	0.82	0.78	0.80	0.79	0.81	0.80	0.81
12 フッ素及びその化合物	0.8mg/l以下	0.08mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
21 塩素酸	0.6mg/l以下	0.06mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
22 クロロ酢酸	0.02mg/l以下	0.002mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
23 クロロホルム	0.06mg/l以下	0.001mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
24 ジクロロ酢酸	0.03mg/l以下	0.003mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
25 ジブromクロロメタン	0.1mg/l以下	0.001mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	0.001	0.002
26 臭素酸	0.01mg/l以下	0.001mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
27 総トリハロメタン	0.1mg/l以下	0.01mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
28 トリクロロ酢酸	0.03mg/l以下	0.003mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
29 プロモジクロロメタン	0.03mg/l以下	0.001mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	0.002
30 プロモホルム	0.09mg/l以下	0.005mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
31 ホルムアルデヒド	0.08mg/l以下	0.008mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
38 塩化物イオン	200mg/l以下	0.2mg/l	8.4	7.6	7.6	7.6	7.4	7.4	7.6	7.7
39 カルシウム、マグネシウム等(硬度)	300mg/l以下	5mg/l	44	35	34	35	33	33	34	33
40 蒸発残留物	500mg/l以下	20mg/l	83	72	76	74	74	68	72	70
46 有機物(全有機炭素(TOC)の量)	3mg/l以下	0.3mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
47 p H	5.8以上8.6以下	—	6.7	6.6	6.6	6.6	6.6	6.6	6.9	7.5
48 味	異常でないこと	—	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし
49 臭気	異常でないこと	—	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし
50 色度	5以下	1度	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
51 濁度	2以下	0.1度	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
残留塩素	遊離0.1mg/l以上	- mg/l	0.3	0.2	0.2	0.3	0.3	0.2	0.4	0.2
遊離炭酸	20mg/l以下(目標値)	0.5mg/l	18.0	12.0	18.0	19.0	18.0	16.0	6.9	N.D.
ランゲリア指数	-1程度極力0(目標値)	—	-2.20	-2.30	-2.30	-2.40	-2.30	-2.30	-2.10	-1.50

※定量下限値未満である場合「N.D.」と表記する。(N.D.:Not Detected(不検出)の略)