

項目	水質基準 (浄水にのみ適用)	定量下限値	千代川系								三宅・千代川系	
			[G]	[H]	[I]	[J]	[K]	[L]	[M]	[N]	[O]	
			千代川浄水場 水質計器室	蕨田野町 佐伯大門 (佐伯加圧ポンプ場)	曾我部町 犬飼 前川	東本橋町 東大谷 生子田	河原林町 勝林島 稲荷	旭町 岩ヶ谷	畑野町 千ヶ畑砂田 (千ヶ畑第1配水池)	畑野町 土ヶ畑谷口 (土ヶ畑第1配水池)	安町 釜ヶ前 (上下水道部庁舎)	
採水日			1	16	8	8	8	8	8	16	16	15
時間			9:25	13:46	10:24	11:07	12:18	11:51	11:42	11:08		12:25
天候			雨	晴	晴	晴	晴	晴	晴	晴	晴	晴
気温			14.3	12.5	12.1	17.0	18.0	18.0	11.8	11.8	11.8	17.2
水温			17.9	17.0	16.2	16.1	18.7	18.8	15.7	15.4	15.4	18.2
区分			浄水	浄水	浄水	浄水	浄水	浄水	浄水	浄水	浄水	浄水
1 一般細菌	100個/ml以下	100個/ml以下	0	0	0	0	0	0	0	0	0	0
2 大腸菌	検出されないこと	—	(-)	(-)	(-)	(-)	(-)	(-)	(-)	(-)	(-)	(-)
3 カドミウム及びその化合物	0.003mg/l以下	0.0003mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
4 水銀及びその化合物	0.0005mg/l以下	0.00005mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
5 セレン及びその化合物	0.01mg/l以下	0.001mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
6 鉛及びその化合物	0.01mg/l以下	0.001mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
7 ヒ素及びその化合物	0.01mg/l以下	0.001mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
8 六価クロム化合物	0.02mg/l以下	0.002mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
9 亜硝酸態窒素	0.04mg/l以下	0.004mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
10 シアン化物イオン及び塩化シアン	0.01mg/l以下	0.001mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
11 硝酸態窒素及び亜硝酸態窒素	10mg/l以下	0.02mg/l	0.74	0.78	0.77	0.73	0.76	0.78	0.77	0.80	0.69	
12 フッ素及びその化合物	0.8mg/l以下	0.08mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
13 ホウ素及びその化合物	1.0mg/l以下	0.02mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
14 四塩化炭素	0.002mg/l以下	0.0002mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
15 1,4-ジオキサン	0.05mg/l以下	0.005mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
16 シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	0.04mg/l以下	0.004mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
17 ジクロロメタン	0.02mg/l以下	0.002mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
18 テトラクロロエチレン	0.01mg/l以下	0.001mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
19 トリクロロエチレン	0.01mg/l以下	0.001mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
20 ベンゼン	0.01mg/l以下	0.001mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
21 塩素酸	0.6mg/l以下	0.06mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
22 クロロ酢酸	0.02mg/l以下	0.002mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
23 クロロホルム	0.06mg/l以下	0.001mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
24 ジクロロ酢酸	0.03mg/l以下	0.003mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
25 ジブromokロロメタン	0.1mg/l以下	0.001mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	0.001	N.D.	N.D.
26 臭素酸	0.01mg/l以下	0.001mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
27 総トリハロメタン	0.1mg/l以下	0.01mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
28 トリクロロ酢酸	0.03mg/l以下	0.003mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
29 プロモジクロロメタン	0.03mg/l以下	0.001mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
30 プロモホルム	0.09mg/l以下	0.005mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
31 ホルムアルデヒド	0.08mg/l以下	0.008mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
32 亜鉛及びその化合物	1.0mg/l以下	0.005mg/l	N.D.	N.D.	0.006	N.D.	0.005	N.D.	N.D.	0.016	0.006	
33 アルミニウム及びその化合物	0.2mg/l以下	0.02mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
34 鉄及びその化合物	0.3mg/l以下	0.03mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
35 銅及びその化合物	1.0mg/l以下	0.01mg/l	N.D.	N.D.	0.01	N.D.	0.02	0.01	N.D.	N.D.	N.D.	N.D.
36 ナトリウム及びその化合物	200mg/l以下	1.0mg/l	6.6	6.9	6.7	6.6	6.6	6.7	6.8	6.9	7.6	
37 マンガン及びその化合物	0.05mg/l以下	0.005mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
38 塩化物イオン	200mg/l以下	0.2mg/l	7.3	7.8	7.6	7.4	7.4	7.5	7.6	7.7	8.4	
39 カルシウム、マグネシウム等(硬度)	300mg/l以下	5mg/l	33.0	36.2	34.7	34.1	33.8	34.7	35.2	35.4	43.9	
40 蒸発残留物	500mg/l以下	20mg/l	65	84	75	66	72	72	82	84	94	
41 陰イオン界面活性剤	0.2mg/l以下	0.02mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
42 ジェオスミン	0.00001mg/l以下	0.000001mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
43 2-メチルイソボルネオール	0.00001mg/l以下	0.000001mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
44 非イオン界面活性剤	0.02mg/l以下	0.005mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
45 フェノール類	0.005mg/l以下	0.0005mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
46 有機物(全有機炭素(TOC)の量)	3mg/l以下	0.3mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
47 pH	5.8以上8.6以下	—	6.56	6.57	6.59	6.56	6.56	6.65	6.80	7.37	6.58	
48 味	異常でないこと	—	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	
49 臭気	異常でないこと	—	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	
50 色度	5以下	1度	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	
51 濁度	2以下	0.1度	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	
残留塩素	遊離0.1mg/l以上	- mg/l	0.35	0.25	0.30	0.30	0.30	0.30	0.35	0.25	0.25	
遊離炭酸	20mg/l以下(目標値)	0.5mg/l	22	21	22	22	20	18	13	6.4	33	
ランゲリア指数	-1程度極力0(目標値)	—	-2.6	-2.5	-2.5	-2.5	-2.5	-2.4	-2.3	-1.7	-2.3	

※定量下限値未満である場合「N.D.」と表記する。(N.D.:Not Detected(不検出)の略)