

令和7年5月度

水質検査結果表(毎月検査)

項目	水質基準 (浄水にのみ適用)	定量下限値	三宅水源					三宅系					
			第3号 取水井	第4号 取水井	第5号 取水井 (旧2-6)	第6号 取水井 (旧2-5)	三宅浄水場 着水井	[A]	[B]	[C]	[D]	[E]	[F]
								三宅浄水場 水質計器室	下矢田町 東法楽寺	篠町 王子唐櫃越 (京都西山霊園)	篠町 王子北垣内 (王子加圧ポンプ場)	篠町 夕日ヶ丘 (篠配水池)	保津町 上火無
採水日			27	27	27	27	27	27	20	27	27	27	13
時間			10:02	10:19	10:40	11:00	11:22	11:33	9:10	12:38	13:02	11:58	9:45
天候			晴	晴	晴	晴	晴	晴	晴	晴	晴	晴	晴
気温			20.8	22.2	22.5	23.1	22.5	22.5	24.5	22.1	23.1	24.8	19.3
水温			16.5	16.0	16.0	15.8	16.2	16.5	19.6	19.0	18.9	19.0	19.2
区分			原水	原水	原水	原水	原水	浄水	浄水	浄水	浄水	浄水	浄水
1 一般細菌	100個/ml以下	0個/ml	0	1	0	0	0	0	0	0	0	0	0
2 大腸菌	検出されないこと	-	(-)	(-)	(-)	(-)	(-)	(-)	(-)	(-)	(-)	(-)	(-)
7 ヒ素及びその化合物	0.01mg/l以下	0.001mg/l						N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
10 シアン化物イオン及び塩化シアン	0.01mg/l以下	0.001mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
11 硝酸態窒素及び亜硝酸態窒素	10mg/l以下	0.02mg/l	0.62	0.68	0.49	0.25	0.58	0.59	0.72	0.58	0.54	0.67	0.61
12 フッ素及びその化合物	0.8mg/l以下	0.08mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
21 塩素酸	0.6mg/l以下	0.06mg/l						N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
22 クロロ酢酸	0.02mg/l以下	0.002mg/l						N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
23 クロロホルム	0.06mg/l以下	0.001mg/l						N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
24 ジクロロ酢酸	0.03mg/l以下	0.003mg/l						N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
25 ジブロモクロロメタン	0.1mg/l以下	0.001mg/l						N.D.	N.D.	0.001	N.D.	0.001	N.D.
26 臭素酸	0.01mg/l以下	0.001mg/l						N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
27 総トリハロメタン	0.1mg/l以下	0.01mg/l						N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
28 トリクロロ酢酸	0.03mg/l以下	0.003mg/l						N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
29 ブロモジクロロメタン	0.03mg/l以下	0.001mg/l						N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
30 ブロモホルム	0.09mg/l以下	0.005mg/l						N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
31 ホルムアルデヒド	0.08mg/l以下	0.008mg/l						N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
38 塩化物イオン	200mg/l以下	0.2mg/l	10.1	9.1	10.2	11.7	10.3	10.2	8.0	9.5	10.8	8.3	9.3
39 カルシウム、マグネシウム等(硬度)	300mg/l以下	5mg/l	57.9	50.2	55.0	60.7	56.8	55.9	38.0	48.8	57.9	40.0	47.3
40 蒸発残留物	500mg/l以下	20mg/l	106	92	98	108	102	104	70	91	102	77	96
46 有機物(全有機炭素(TOC)の量)	3mg/l以下	0.3mg/l	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
47 pH	5.8以上8.6以下	-	6.48	6.53	6.48	6.65	6.52	6.50	6.65	6.84	6.60	6.94	7.04
48 味	異常でないこと	-						異常なし	異常なし	異常なし	異常なし	異常なし	異常なし
49 臭気	異常でないこと	-	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし
50 色度	5以下	1度	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
51 濁度	2以下	0.1度	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
残留塩素	遊離0.1mg/l以上	- mg/l						0.30	0.20	0.15	0.25	0.20	0.20
遊離炭酸	20mg/l以下(目標値)	0.5mg/l	34	27	36	31	34	31	16	13	30	4.5	5.3
ランゲリア指数	-1程度極力0(目標値)	-	-2.2	-2.3	-2.2	-2.0	-2.2	-2.2	-2.4	-1.9	-2.0	-2.0	-1.8
嫌気性芽胞菌	検出されないこと	-	(-)	(-)	(-)	(-)	(-)						

※定量下限値未満である場合「N.D.」と表記する。(N.D.:Not Detected(不検出)の略)